

Specification for

Steel conduit and fittings with metric threads of ISO form for electrical installations —

**Part 1: Steel conduit, bends and
couplers**

UDC 621.315.67

Co-operating organizations

The Electrical Industry Standards Committee under whose supervision this British Standard was prepared consists of representatives from the following Government departments and scientific and industrial organizations:

- Associated Offices' Technical Committee
- Association of Consulting Engineers*
- Association of Mining Electrical and Mechanical Engineers
- Association of Supervising Electrical Engineers*
- British Electrical and Allied Manufacturers' Association*
- British Railways Board
- British Radio Equipment Manufacturers' Association
- Crown Agents for Overseas Governments and Administrations
- Department of Employment and Productivity*
- Electric Cable Makers' Confederation
- Lighting Industry Federation Limited
- Electrical Contractors' Association (Incorporated)*
- Electrical Contractors' Association of Scotland
- Electrical Research Association
- Electricity Council, the Central Electricity Generating Board and the Area Boards in England and Wales*
- Electronic Engineering Association
- Engineering Equipment Users' Association
- Institution of Electrical Engineers*
- Ministry of Technology
- Ministry of Defence
- Ministry of Defence, Army Department
- Ministry of Defence, Navy Department
- Ministry of Power
- Ministry of Public Building and Works*
- Municipal Passenger Transport Association (Incorporated)
- National Inspection Council for Electrical Installation Contracting
- National Physical Laboratory (Ministry of Technology)
- Oil Companies Materials Association
- Post Office*
- Public Transport Association (Incorporated)
- South of Scotland Electricity Board

The Government departments and scientific and industrial organizations marked with an asterisk in the above list, together with the following, were directly represented on the committees entrusted with the preparation of this British Standard:

- Aluminium Federation
- British Electric Conduit Systems Manufacturers
- British Plastics Federation
- Light Metal Founders' Association
- Confederation of British Industry
- Zinc Development Association

This British Standard, having been approved by the Electrical Industry Standards Committee, was published under the authority of the Executive Board on 27 February 1970

© BSI 11-1999

The following BSI references relate to the work on this standard:
Committee reference ELE/80
Draft for comment D65/12020

ISBN 580 05747 X

Amendments issued since publication

Amd. No.	Date	Comments
1132	March 1973	
5384	January 1987	Indicated by a sideline in the margin

Contents

	Page
Co-operating organizations	Inside front cover
Foreword	ii
1 Scope	1
2 General requirements	1
3 General conditions for the tests described in Appendix A	1
4 Classification	1
5 Marking	1
6 Dimensions	2
7 Construction	2
8 Mechanical properties of conduit	2
9 Resistance to corrosion	2
10 Electrical continuity	2
11 Test for fittings of malleable cast iron	2
Appendix A Tests	3
A.1 Test for durability of marking	3
A.2 Test of mechanical properties of conduit	3
A.3 Tests for resistance to corrosion	3
A.4 Requirements for the efficiency of the conduit/fitting conducting path	4
A.5 Tests for malleable cast iron fittings	4
Figure 1 — Screw threads, profile	5
Figure 2 — Gauges for screw threads on conduits	7
Figure 3 — Gauges for screw threads in fittings	9
Figure 4 — Gauges for checking the outside diameter of conduits	11
Figure 5 — Gauges for checking permissible ovality of conduits	12
Figure 6 — Bending tool	13
Standard Sheets	
1 Conduits, light gauge, (plain)	14
2 Conduits, heavy gauge, (screwed or plain)	15
3 Couplers, plain	16
4 Bends, plain	17
5 Bends, internally plain	18
6 Couplers, internally screwed	19
7 Bends, externally screwed	20

Foreword

This British Standard has been prepared under the authority of the Electrical Industry Standards Committee and is in close agreement with Publication 23, “*Steel conduit and fittings for electrical installations*”, issued by the International Commission on rules for the approval of Electrical Equipment (CEE). The 19 and 20 mm sizes of the 1962 edition of CEE 23 will be replaced by a single 20 mm size when it is next revised.

An important feature of the CEE Specification is the adoption of a series of conduit diameters which will also apply to the conduit entries into all types of electrical enclosures and fittings.

This standard is similar in scope to BS 31, “*Steel conduit and fittings for electrical wiring*” and specifies both plain and screwed conduit and fittings.

The wall thickness of the conduit, however, has in some cases been reduced for that specified in BS 31 for conduit of similar external diameters owing to the employment of a 60° thread on the tube based on the ISO thread form.

Conduit and fittings described in this standard will be alternative to, and eventually supersede, those complying with BS 31, with the ultimate object of unification with the standards of other European countries.

Additionally, when preparing this standard, full consideration was given to proposals received for revisions needed to BS 31, and, where desirable, the necessary amendments have been incorporated.

This standard has been divided into two parts:

- *Part 1: Steel conduit, bends and couplers;*
- *Part 2: Steel conduit fittings and components.*

This part of the standard specifies requirements for conduit and those bends and couplers which have been standardized internationally and are covered by CEE Specification No. 23.

Part 2 specifies fittings and components not at present standardized internationally, but which have found wide practical application.

In both parts, the range of conduit diameters included is from 16 mm to 32 mm outside diameter. Consideration will be given to the inclusion of larger sizes when they have been standardized internationally.

A British Standard does not purport to include all the necessary provisions of a contract. Users of British Standards are responsible for their correct application.

Compliance with a British Standard does not of itself confer immunity from legal obligations.

Summary of pages

This document comprises a front cover, an inside front cover, pages i and ii, pages 1 to 20 and a back cover.

This standard has been updated (see copyright date) and may have had amendments incorporated. This will be indicated in the amendment table on the inside front cover.

1 Scope

This part of this British Standard specifies requirements for steel conduits, and for conduit fittings of steel or malleable cast iron, intended for the protection of cables in electrical installations.

2 General requirements

2.1 Conduits and fittings shall be so designed and constructed that they are not adversely affected by transport and storage, and assure reliable mechanical protection to the cables.

2.2 Conduit fittings shall be either of the screwed type, which are threaded for connection to heavy-gauge conduits, or of the plain non-screwed type which are primarily designed for use with non-screwed light gauge conduit.

2.3 TEST. In general, compliance with **2.1** and **2.2** shall be checked by carrying out all the tests specified.

3 General conditions for the tests described in Appendix A

3.1 The tests specified in this standard are type tests.

3.2 Unless otherwise specified, tests shall be made at an ambient temperature of 20 ± 5 °C.

3.3 Each test shall be made on three samples. For conduits, three manufactured lengths taken at random are required, the samples for the various tests being taken, one from each length.

3.4 Conduits and fittings shall be deemed not to comply with this standard if more than one sample fails any one of the tests. If one sample fails in a test, that test shall be repeated on a second set of three samples, all of which shall comply with the repeated tests. If any sample fails in the retest, then all the samples shall be deemed to have failed to comply with the standard.

For conduits, the second set of samples shall be taken from other lengths.

NOTE The applicant may submit, together with the first set of conduit samples, the additional set which may be required should one sample fail.

The testing station will then, without further request, test the additional samples and will only reject if a further failure occurs. If the additional set of samples is not submitted at the same time, a failure of one sample will entail a rejection.

4 Classification

4.1 Conduits and fittings are classified, as follows, according to the method of assembly with the fittings:

- 1) Plain conduits and fittings.
- 2) Screwed conduits and fittings.

4.2 Conduit and fittings are further classified, as follows, according to the type of protection applied:

Class 1. Light protection both inside and outside.	<i>Example:</i> priming paint.
Class 2. Medium protection both inside and outside.	<i>Example:</i> stoved enamel; air-drying paint.
Class 3. Medium heavy protection. Inside as Class 2, outside as Class 4.	<i>Example:</i> stoved enamel inside. Sherardized outside.
Class 4. Heavy protection both inside and outside.	<i>Example:</i> hot-dip zinc coating, sherardizing.

5 Marking

5.1 Conduits shall be marked with the following:

- 1) The name or identification mark of the maker or responsible vendor.
- 2) The number of this British Standard.
- 3) The class of finish.

The marking shall be near to one end of each conduit length.

5.2 Fittings, excluding couplers supplied with a length of conduit, shall be identified either by marking on the fittings or on the package containing them as follows:

- 1) The name or identification mark of the maker, or responsible vendor.
- 2) The number of this British Standard.
- 3) The type reference (see Note below) or description.
- 4) The material from which the fitting is made or a suitable abbreviation.

5.3 The marking, whether on the fitting or the package, shall be easily legible. If on the conduit or fitting it shall also be durable.

5.4 TEST. Compliance with the requirements of **5.1** to **5.3** shall be checked by inspection and, for marking on conduit and fittings, by the durability of marking test described in Appendix **A.1**.

NOTE 1 The type reference comprises the number of the British Standard, the Standard Sheet number for the fitting, and the size in mm. Example, BS/0000/7/25.

6 Dimensions

6.1 Conduit. The outside diameters, wall thicknesses and tolerances for the manufacture of conduits shall be as stated in Standard Sheets 1 and 2. Screw threads shall comply with the basic dimensions given in Figure 1.

6.1.1 TEST. Compliance shall be checked as follows:

- 1) *External diameter* by using gauges as shown in Figure 4.
- 2) *Ovality* by using gauges as shown in Figure 5.
- 3) *Screw threads* by using gauges as shown in Figure 2.
- 4) *Wall thickness* by taking the average weights of three manufactured lengths of conduit and then comparing with the table of weights as given on Standard Sheets 1 or 2, as appropriate.

6.2 Fittings. Fittings shall comply with the Standard Sheets detailed below:

Couplers, plain:	Sheet No. 3
Bends, plain:	Sheet No. 4
Bends, plain internally:	Sheet No. 5
Couplers, screwed:	Sheet No. 6
Bends, externally screwed:	Sheet No. 7

Screw threads shall comply with the basic dimensions given in Figure 1.

6.2.1 TEST. Compliance shall be checked by measurement and, for screw threads, by using gauges shown in Figure 2 and Figure 3.

6.3 Tolerances. All dimensions on Standard Sheets except those for which tolerances are specifically stated, or for which maxima and/or minima are given, shall be regarded as nominal dimensions and subject to a tolerance of plus or minus 5 %.

6.3.1 When the wall thickness is given as a nominal dimension (with or without tolerances) such thickness applies to the material from which the product is made. All other dimensions apply to the finished product.

7 Construction

7.1 Conduits shall be solid drawn or seamed by welding.

7.2 Conduits shall show no appreciable unevenness and their interior and ends shall be free from burrs, fins and the like which may cause damage to cables.

7.3 The interior and ends of fittings shall be free from burrs, fins and the like. Surfaces and edges over which the cables are likely to be drawn shall be smooth and well rounded.

7.4 TEST. Compliance with the requirements of **7.1** and **7.2** shall be checked by inspection. In case of doubt, the sample shall be cut into short pieces and, if necessary, these shall be cut longitudinally. Slight protrusions from welded seams shall be neglected if they are unlikely to cause damage to cables.

8 Mechanical properties of conduit

8.1 Conduits when bent shall show no cracks and shall not be deformed to such an extent that introduction of the cables becomes difficult, or that they are damaged when drawing in.

8.1.1 TEST. Compliance shall be checked by inspection and by the bending test described in Appendix **A.2**, except that plain conduits exceeding 25 mm diameter shall not be subjected to the bending test.

9 Resistance to corrosion

9.1 Conduit and fittings, excluding screw threads, shall be adequately protected against corrosion, both inside and outside.

9.1.1 TEST. Compliance shall be checked by the appropriate test or tests described in Appendix **A.3**, which describes tests for light, medium, and heavy protection.

For Class 3 conduit and fittings, the inside and outside protective coatings shall separately comply with the relevant tests described in Appendix **A.3**.

Conduit and fittings may be split to the extent considered necessary to allow adequate examination of their interior surfaces.

10 Electrical continuity

10.1 Fittings intended for an installation where an electrically continuous path is required throughout the assembly of conduit and fittings shall be so constructed that they comply with the requirements described in Appendix **A.4**.

10.2 Fittings for plain conduit require special devices to ensure permanent and reliable metallic contact between fitting and conduit. In some designs this may involve removal of the protective finish from the conduit and fitting at the point where metallic contact is to be established.

11 Test for fittings of malleable cast iron

Fittings manufactured from malleable cast iron shall comply with the test requirements described in Appendix **A.5**.

Appendix A Tests of conduits and fittings

A.1 Test for durability of marking

Durability shall be checked by rubbing the marking by hand for 15 seconds with a piece of cloth soaked with water and again for 15 seconds with a piece of cloth soaked with petroleum spirit. After the test the marking shall remain legible.

NOTE Marking may be achieved by, for example, stamping, printing, adhesive labels, or waterslide transfers.

A.2 Test of mechanical properties of conduit

The conduits are bent through 90° using a bending tool having a radius equal to six times the nominal size.

For conduits not exceeding the nominal size of 25 mm, a tool shown in Figure 6 shall be used.

For conduits exceeding the nominal size of 25 mm an appropriate bending machine shall be used.

For conduits with welded seam, six samples shall be tested, three with the seam on the outside of the bend, and three with the seam on the flank.

After the test, neither the basic material of the conduits, nor the coating of conduits with medium or heavy protection, shall show any cracks visible to the naked eye. The seams, if any, shall not have opened, and the section of the conduit shall not have distorted unduly.

The distortion of the section shall be judged as follows:

The bent conduit shall be held in a vertical plane, the bend being symmetrically disposed in relation to the horizontal. It shall then be possible to roll a polished steel ball, having a diameter as specified below, through the conduit.

Nominal size	Diameter of test ball		Tolerance (Plus or minus)
	Plain conduit	Screwed conduit	
mm	mm	mm	mm
16	10.30	9.50	0.02
20	14.00	13.00	0.02
25	17.00	16.00	0.02
32	—	22.00	0.02

The diameters of the balls have been so chosen that standardized bearing balls can be used.

A.3 Tests for resistance to corrosion

A.3.1 Light protection. Samples of conduit with light protection shall be slowly bent round a smooth cylindrical mandrel having a radius equal to:

- 1) Ten times the normal conduit diameter for conduit not exceeding a nominal diameter of 25 mm.
- 2) Twelve times the nominal diameter for other conduits.

A sheet of cardboard or the like, about 3 mm thick shall be placed between the conduit and the mandrel. After this test the coating of the conduit shall show no sign of damage. Fittings shall be inspected for completeness of covering by the protective coating, both inside and outside.

A.3.2 Medium protection. Samples of conduit shall be bent as described in A.2, cleaned with a piece of wadding soaked in benzene and then dried. The bent part of each sample shall then be immersed in a solution of 0.75 % potassium ferricyanide ($K_3Fe(CN)_6$) and 0.25 % ammonium persulphate ($(NH_4)_2S_2O_8$) in water and a quantity of about 0.1 % of a suitable wetting agent, for instance a sodium salt of an alkyl naphthalene sulphonic acid, shall be added.

Fittings with medium protection shall be cleaned in the manner described above for conduit and shall then be totally immersed in the solution. The solution and samples are maintained at a temperature of 20 ± 1 °C.

Each sample shall be tested separately, a fresh solution being used each time.

After immersion for 5 minutes, the samples shall be removed from the solution and left to dry at room temperature in air. After completion of the test as described above, the samples shall show no more than two blue coloured spots on each square centimetre of the surface, and no blue spot shall have a dimension larger than 1.5 mm. Traces of rust on sharp edges, screw threads and machined surfaces, also any yellowish film removable by rubbing, shall be ignored.

A.3.3 Heavy protection. Samples of conduit shall be bent as described in A.2, degreased by immersion in trichloroethylene in accordance with BS 580¹⁾ for 10 minutes and wiped dry with a piece of soft cloth. They shall then be immersed in a 2 % solution of sulphuric acid in water for 15 seconds, thoroughly cleaned in running water and again wiped dry with a piece of clean soft cloth.

¹⁾ BS 580 "Trichloroethylene".

The bent part of each sample shall then be immersed in a solution of copper sulphate ($\text{CuSO}_4 \cdot 5\text{H}_2\text{O}$) in distilled water, having a specific gravity of 1.186 at 20 °C.

Fittings with heavy protection shall be degreased as described above for conduit and then totally immersed in the solution. The solution and the samples shall be maintained at a temperature of 20 ± 1 °C, without stirring.

NOTE The solution is made by dissolving 360 grammes of crystalline copper sulphate in 1 litre of distilled water, and neutralizing with copper carbonate or copper hydroxide (about 1 g/l). The specific gravity is then checked and adjusted as necessary.

The container shall be such that it will not react with the solution and shall be of such a size as to provide clearance of at least 25 mm between the walls thereof and the sample.

Each sample shall be immersed four times in succession in the same solution, each time for 1 minute. A fresh solution shall be used for each sample. After each immersion, the sample shall immediately be cleaned in running water with a brush to remove any black deposit. The sample shall then be wiped dry with a piece of clean soft cloth and, except after the fourth immersion, returned to the solution. Care should be taken to clean out all holes and pockets.

After the test, the sample shall show no precipitation of copper which cannot be scrubbed off in running water, if necessary after immersion in a 10 % solution of hydrochloric acid in water for 15 seconds.

Traces of copper precipitation on screw threads, sharp edges and machined surfaces may be ignored.

A.4 Requirements for the efficiency of the conduit/fitting conducting path

An arrangement of conduit and fittings consisting of ten plain (i.e. non-screwed) conduit lengths coupled together by fittings not less than 25 mm apart shall be assembled (with their continuity devices, where applicable) in the manner of use as designed.

They shall then be tested for continuity between the ends of the assembly. The resistance so measured shall not exceed 0.05 Ω .

A.5 Test for malleable cast iron fittings

Test pieces are cut from the fitting and shall be the configuration of half, or slightly less than half, of an open ended cylinder. Alternatively, in the case of a coupler, the whole fitting may conveniently be used.

The test sample shall be capable of being pressed flat without showing signs of cracking when compressed diametrically between two smooth parallel faces having a width of not less than half the original circumference of the specimen, and a length not less than the length of the specimen.





Table of thread details for Figure 1
Based upon British Standard BS 3643-3 Table 6 and Table 7
Conduit Tolerance class 8g (Free fit)

All dimensions are in millimetres.

Size	Major diameter D			Effective diameter d_2			Minor diameter d_1		
	Max.	Tolerance	Min.	Max.	Tolerance	Min.	Max.	Tolerance	Min.
16	15.968	0.375	15.593	14.994	0.224	14.770	14.127	0.332	13.795
20	19.968	0.375	19.593	18.994	0.224	18.770	18.127	0.332	17.795
25	24.968	0.375	24.593	23.994	0.236	23.758	23.127	0.344	22.783
32	31.968	0.375	31.593	30.994	0.236	30.758	30.127	0.344	29.783
Fittings Tolerance class 7H (free fit)									
Size	Major diameter D			Effective diameter D_2			Minor diameter D_1		
	Min.			Max.	Tolerance	Min.	Max.	Tolerance	Min.
16	16.000			15.262	0.236	15.026	14.751	0.375	14.376
20	20.000			19.262	0.236	19.026	18.751	0.375	18.376
25	25.000			24.276	0.250	24.026	23.751	0.375	23.376
32	32.000			31.276	0.250	31.026	30.751	0.375	30.376
NOTE The above thread details are given for information only. For the purposes of the specification, compliance shall be checked by the use of the gauges shown in Figure 2 and Figure 3.									



For dimensions see table.



It shall be possible, without undue force, to screw the thread gauge on to the conduit. It shall not be possible, without undue force, to pass the plain gauge over the thread.

Figure 2 — Gauges for screw threads on conduits

Table of dimensions of gauges on Figure 2
(Profile as Figure 2)

All dimensions are in millimetres.

Designation of gauge	Nominal size of conduit	“GO” threaded ring gauge						“NOT GO” plain ring gauge		Overall diameter of gauge <i>D</i> ₃	Thickness of gauge <i>B</i>
		Minor diameter <i>d</i> ₁	Tolerance	Pitch (effective) diameter	Tolerance	Pitch ^a tolerance	Tolerance on flank angle (Minutes)	Diameter of hole <i>D</i> _a	Tolerance		
CM16	16	14.344	± 0.012	14.994	+0.000 −0.024	0.005	± 12	15.593	± 0.015	45	12
CM20	20	18.344	± 0.012	18.994	+0.000 −0.024	0.005	± 12	19.593	± 0.015	45	12
CM25	25	23.344	± 0.012	23.994	+0.000 −0.024	0.005	± 12	24.593	± 0.015	60	16
CM32	32	30.344	± 0.012	30.994	+0.000 −0.024	0.005	± 12	31.593	± 0.015	63	16
NOTE The tolerances of these gauges are as shown in the relevant sections of BS 919-3.											
^a The pitch tolerance is the maximum permissible error between any two threads over the full length of the gauge, irrespective of sign.											



For dimensions see table.

It shall be possible to screw the gauge into the fitting without using undue force. It shall not be possible, without undue force, to insert the plain gauge into the fitting.

NOTE This drawing does not purport to show unessential constructional details. For example, the two ends of the gauge may be separate units.


Figure 3 — Gauges for screw threads in fittings

Table of dimensions of gauges on Figure 3
(Profile as Figure 3)

All dimensions are in millimetres.

Designation of gauge	Nominal size of fitting	“GO” threaded plug gauge						“NOT GO” plain gauge		Length of gauging portion of threaded gauge L_1	Length of gauging portion of plain gauge L_2
		Major diameter	Tolerance	Effective (pitch) diameter	Tolerance	Pitch tolerance ^a	Tolerance on flank angle (Minutes)	Diameter of plug D_a	Tolerance		
CM16	16	16.000	+0.030 +0.002	15.026	+0.023 +0.009	0.005	± 12	14.751	± 0.008	18	8
CM20	20	20.000	+0.030 +0.002	19.026	+0.023 +0.009	0.005	± 12	18.751	± 0.008	20	8
CM25	25	25.000	+0.030 +0.002	24.026	+0.023 +0.009	0.005	± 12	23.751	± 0.008	22	9
CM32	32	32.000	+0.030 +0.002	31.026	+0.023 +0.009	0.005	± 12	30.751	± 0.008	25	10
NOTE The tolerances of these gauges are as shown in the relevant sections of BS 919-3.											
^a The pitch tolerance is the maximum permissible error between any two threads over the full length of the gauge, irrespective of sign.											

Size designation (e.g. CM 16)
to be marked on gauge.





It shall be possible, without undue force, to slide the gauge completely over the conduit.

All dimensions are in millimetres.

Designation of gauge	Nominal size of conduit	d_g	Manufacturing tolerance	Admissible wear	b	d
CM16	16	16.04	- 0.01	+ 0.01	12	45
CM20	20	20.04	- 0.01	+ 0.01	12	45
CM25	25	25.04	- 0.01	+ 0.01	16	60
CM32	32	32.04	- 0.01	+ 0.01	18	70

Figure 4 — Gauges for checking the outside diameter of conduits





All dimensions are in millimetres.


Nominal size of conduit	Bending radius		Radius of groove r
	Inside R	Outside R_1	
16	96	113	8.1
20	120	141	10.2
25	150	178	12.9

Figure 6 — Bending tool

Material
Steel

Conduit, light gauge
(Plain)

Standard
Sheet
1



Nominal size	Dimensions (mm)			Weight (g/m)			
	A		B	Class 1, 2 and 3		Class 4	
	Min.	Max.		Min.	Max.	Min.	Max.
16	15.7	16.0	1.0 ± 0.10	324	405	355	470
20	19.7	20.0	1.0 ± 0.10	416	515	457	597
25	24.6	25.0	1.2 ± 0.15	598	784	649	887
32	31.6	32.0	1.2 ± 0.15	796	1 006	861	1 139

Preferred length of conduit 4.0 m. Minimum 3.0 m. Maximum 4.0 m.

Material Steel	Conduit, heavy gauge (Screwed or plain)				Standard Sheet 2			
-------------------	--	--	--	--	------------------------	--	--	--

Runout of thread $\approx 3 \text{ mm.}$

A dia.


B

C length of full thread

Nominal size	Dimensions (mm)					Weights (g/m)			
	A		B	C		Class 1, 2 and 3		Class 4	
	Min.	Max.		Min.	Max.	Min.	Max.	Min.	Max.
16	15.7	16.0	1.4 ± 0.10	11.5	13.5	452	531	483	594
20	19.7	20.0	1.6 ± 0.15	13.0	15.0	643	783	682	862
25	24.6	25.0	1.6 ± 0.15	16.0	18.0	811	995	860	1 095
32	31.6	32.0	1.6 ± 0.15	18.0	20.0	1 069	1 301	1 133	1 432

Preferred length of conduit 4.0 m. Minimum 3.0 m. Maximum 4.0 m.


NOTE Screw threads in accordance with Figure 1.

Material Steel	Couplers (Plain)				Standard Sheet 3																																															
 All dimensions are in millimetres. <table><tr><th rowspan="2">Nominal size</th><th colspan="2">Inside diameter of collar <i>A</i></th><th rowspan="2">Minimum wall thickness <i>B</i></th><th colspan="2">Minimum overall length</th><th colspan="2">Inside diameter of ridge <i>D</i></th></tr><tr><th>Min.</th><th>Max.</th><th>Short couplers <i>C</i></th><th>Long couplers <i>C</i></th><th>Max.</th><th>Min.</th></tr><tr><td>16</td><td>16.1</td><td>16.5</td><td>0.90</td><td>46</td><td>80</td><td>14.7</td><td>14.3</td></tr><tr><td>20</td><td>20.1</td><td>20.5</td><td>0.90</td><td>52</td><td>80</td><td>18.7</td><td>18.3</td></tr><tr><td>25</td><td>25.2</td><td>25.7</td><td>1.05</td><td>58</td><td>80</td><td>23.6</td><td>23.1</td></tr><tr><td>32</td><td>32.2</td><td>32.7</td><td>1.05</td><td>64</td><td>100</td><td>30.1</td><td>29.6</td></tr></table>							Nominal size	Inside diameter of collar <i>A</i>		Minimum wall thickness <i>B</i>	Minimum overall length		Inside diameter of ridge <i>D</i>		Min.	Max.	Short couplers <i>C</i>	Long couplers <i>C</i>	Max.	Min.	16	16.1	16.5	0.90	46	80	14.7	14.3	20	20.1	20.5	0.90	52	80	18.7	18.3	25	25.2	25.7	1.05	58	80	23.6	23.1	32	32.2	32.7	1.05	64	100	30.1	29.6
Nominal size	Inside diameter of collar <i>A</i>		Minimum wall thickness <i>B</i>	Minimum overall length		Inside diameter of ridge <i>D</i>																																														
	Min.	Max.		Short couplers <i>C</i>	Long couplers <i>C</i>	Max.	Min.																																													
16	16.1	16.5	0.90	46	80	14.7	14.3																																													
20	20.1	20.5	0.90	52	80	18.7	18.3																																													
25	25.2	25.7	1.05	58	80	23.6	23.1																																													
32	32.2	32.7	1.05	64	100	30.1	29.6																																													

Material
Steel

Bends
(Plain)

Standard
Sheet
4



All dimensions are in millimetres.

Nominal size	A min.	B min.	Outside diameter C		D min.	Wall thickness E
			max.	min.		
16	40.0	72.0	16.0	15.7	22.0	1.0 ± 0.10
20	50.0	90.0	20.0	19.7	25.0	1.0 ± 0.10
25	62.5	110.0	25.0	24.6	28.0	1.2 ± 0.15
32	80.0	144.0	32.0	31.6	31.0	1.2 ± 0.15

Material
Steel

Bends
(Internally plain)

Standard
Sheet
5

The diagram illustrates a 90-degree bend in a steel pipe. Key dimensions and features include:

- A rad.**: The radius of the bend.
- B**: The length of the straight sections on either side of the bend.
- C dia.**: The inside diameter of the collar.
- D**: The length of the collar.
- E**: The wall thickness of the pipe.
- F dia.**: The inside diameter of the ridge.
- 90°**: The angle of the bend.
- ≈ 3**: A small dimension at the top of the bend.

All dimensions are in millimetres.


Nominal size	A min.	B min.	Inside diameter of collar C		Min. length of collar D		Wall thickness E min.	Inside diameter of ridge F	
			Min.	Max.	Short	Long		Max.	Min.
16	40.0	72.0	16.1	16.5	22.0	40.0	0.9	14.7	14.3
20	50.0	90.0	20.1	20.5	25.0	40.0	0.9	18.7	18.3
25	62.5	110.0	25.2	25.7	28.0	40.0	1.05	23.6	23.1
32	80.0	144.0	32.2	32.7	31.0	50.0	1.05	30.1	29.6

Material
Mall cast
iron or steel

Couplers (Internally screwed)

Standard
Sheet
6

For tolerances see clause 6
Screw threads to Figure 1.



Earthing Couplers. These have an integral device for clamping an earthing conductor ranging from cross-sectional area of 1.5 mm² to 6 mm². The method of gripping shall be such that no adverse damage to the conductor will result.

All dimensions are in millimetres.

Metric dimensions			
Nominal size	A (minimum)	B (minimum)	
		Mall.	Steel
16	30	19.2	17.5
20	33	23.2	21.5
25	39	28.4	26.7
32	43	35.6	33.8

Material Steel or Mall Cast Iron	Bends (Externally screwed)	Standard Sheet 7
--	-------------------------------	------------------------

All dimensions are in millimetres.

Nominal size	A min.	B min.	Outside diameter C		Length of thread D	Wall thickness E
			Max.	Min.		
16	40.0	72.0	16.0	15.7	12.5 ± 1.0	1.4 ± 0.10
20	50.0	90.0	20.0	19.7	14.0 ± 1.0	1.6 ± 0.15
25	62.5	110.0	25.0	24.6	17.0 ± 1.0	1.6 ± 0.15
32	80.0	144.0	32.0	31.6	19.0 ± 1.0	1.6 ± 0.15

BSI — British Standards Institution

BSI is the independent national body responsible for preparing British Standards. It presents the UK view on standards in Europe and at the international level. It is incorporated by Royal Charter.

Revisions

British Standards are updated by amendment or revision. Users of British Standards should make sure that they possess the latest amendments or editions.

It is the constant aim of BSI to improve the quality of our products and services. We would be grateful if anyone finding an inaccuracy or ambiguity while using this British Standard would inform the Secretary of the technical committee responsible, the identity of which can be found on the inside front cover. Tel: 020 8996 9000. Fax: 020 8996 7400.

BSI offers members an individual updating service called PLUS which ensures that subscribers automatically receive the latest editions of standards.

Buying standards

Orders for all BSI, international and foreign standards publications should be addressed to Customer Services. Tel: 020 8996 9001. Fax: 020 8996 7001.

In response to orders for international standards, it is BSI policy to supply the BSI implementation of those that have been published as British Standards, unless otherwise requested.

Information on standards

BSI provides a wide range of information on national, European and international standards through its Library and its Technical Help to Exporters Service. Various BSI electronic information services are also available which give details on all its products and services. Contact the Information Centre. Tel: 020 8996 7111. Fax: 020 8996 7048.

Subscribing members of BSI are kept up to date with standards developments and receive substantial discounts on the purchase price of standards. For details of these and other benefits contact Membership Administration. Tel: 020 8996 7002. Fax: 020 8996 7001.

Copyright

Copyright subsists in all BSI publications. BSI also holds the copyright, in the UK, of the publications of the international standardization bodies. Except as permitted under the Copyright, Designs and Patents Act 1988 no extract may be reproduced, stored in a retrieval system or transmitted in any form or by any means – electronic, photocopying, recording or otherwise – without prior written permission from BSI.

This does not preclude the free use, in the course of implementing the standard, of necessary details such as symbols, and size, type or grade designations. If these details are to be used for any other purpose than implementation then the prior written permission of BSI must be obtained.

If permission is granted, the terms may include royalty payments or a licensing agreement. Details and advice can be obtained from the Copyright Manager. Tel: 020 8996 7070.